



TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.
Technical and Test Institute for Construction Prague, SOE

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznamovaný subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán • Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body • Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Branch 0300 – Pilsen

CERTIFICATE

No. 030 – 060238

About the qualities of a product

Certified quality: SLIPPERINESS according to the following test procedures:

DIN 51097 Testing of floor coverings; determination of anti – slip properties wet-loaded barefoot areas; walking method – ramp test

Product: Ceramic tiles dry-pressed, EN 14411, Annex G, group BI_a

type: **GIGANT 2.0** 59,3 x 59,3 cm

type: **GIGANT ANTHRACITE 2.0** 59,3 x 59,3 cm

Producer: CERSANIT S.A., Al. Solidarności 36, 25-323 Kielce, Poland

Production plant: CERSANIT S.A., Production Plant Opoczno, Ul. Przemysłowa 5, 26-300 Opoczno, Poland

Customer: CERSANIT S.A., Al. Solidarności 36, 25-323 Kielce, Poland

Order: Z 030200209

Achieved values:

| testing samples | Critical angle of slip classification according DIN 51097 (barefoot) |
|---|--|
| GIGANT 2.0 59,3 x 59,3 cm | >24° C |
| GIGANT ANTHRACITE 2.0 59,3 x 59,3 cm | >24° C |

The certificate is issued on the basis of the results of the tests stated in report no. 030–055425 from 24th July 2017. The certificate is extended the period of validity based on the manufacturer's assertion that the manufacturing technology remains unchanged.

Number of pages of certificate: 1

Certificate validity: **till 30th June 2023**

The certificate can be cancelled upon finding non-adherence to the certified parameters of product qualities.



Stamp of ZÚS – branch Pilsen

Ing. Alexander Trinner

Branch Director

Pilsen 23rd June 2020

Warning: Without a written consent of the representative of the head of the authorised person, this report must not reproduced otherwise than in its entirety.

Technical and testing construction institute Prague, state enterprise, branch 0300 - Pilsen, Zahradni 15, 326 00 Pilsen, Czech Republic
☎: 377 243 331, ☎: 377 430 345, Fax: +420 377 430 347, Internat.: +420 377 244 158, ✉ e-mail: babkova@tzus.cz, www.tzus.cz
Banking details: KB Prague 1 Czech Republic, account number: 1501-931/0100 Co. Id. No.: 000 15679 Tax Co. Id. No.: CZ-00015679