



TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.
Technical and Test Institute for Construction Prague, SOE

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznamovaný subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán • Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body • Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Branch 0300 – Pilsen

CERTIFICATE

No. 030 – 057700

About the qualities of a product

Certified quality: SLIPPERINESS according to the following test procedures:

DIN 51097: 1992

Testing of floor coverings determination of anti – slip properties wet-loaded barefoot areas; walking method – ramp test

P CEN/TS 16165: 2013

Determination of slip resistance of pedestrian surfaces – Methods of evaluation

Product:

Ceramic tiles dry-pressed, EN 14411, Annex G, group BIa
type: GRAND WOOD (NATURAL, PRIME, RUSTIC) 19,8x119,8 cm

Producer:

CERSANIT S.A., Al. Solidarności 36, 25-323 Kielce, Poland

Production plant:

OPOCZNO I SP. Z O.O., Ul. Przemysłowa 5, 26-300 Opoczno, Poland

Customer:

CERSANIT S.A., Al. Solidarności 36, 25-323 Kielce, Poland

Order:

Z 030180451

Achieved values:

testing samples	Critical angle of slip classification according DIN 51097 (barefoot), P CEN/TS 16165 (annex A)
GRAND WOOD (NATURAL, PRIME, RUSTIC) 19,8x119,8 cm	23° B

The certificate is issued on the basis of the results of the tests stated in report no. 030–057604.

Number of pages of certificate: 1

Certificate validity:

till 30th November 2021

The certificate can be cancelled upon finding non-adherence to the certified parameters of product qualities.

Pilsen 28th November 2018



Stamp of ZÚS – branch Pilsen

Ing. Alexander Trinner
Branch Director

Warning: Without a written consent of the representative of the head of the authorised person, this report must not reproduced otherwise than in its entirety.

Technical and testing construction institute Prague, state enterprise, branch 0300 - Pilsen, Zahradní 15, 326 00 Pilsen, Czech Republic
☎: 377 243 331, ☎: 377 430 345, Fax:+420 377 430 347, Internat.:+420 377 244 158, ✉ e-mail: kotorova@tzus.cz, www.tzus.cz
Banking details: KB Prague 1 Czech Republic, account number: 1501-931/0100 Co. Id. No.: 000 15679 Tax Co. Id. No.: CZ-00015679