



**TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.**  
**Technical and Test Institute for Construction Prague, SOE**

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznamovaný subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán • Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body • Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Branch 0300 – Pilsen

# CERTIFICATE

No. 030 – 057889

## about the qualities of a product

**Certified quality:** **SLIPPERINESS** according to the following test procedures:

**DIN 51097: 1992**

Testing of floor coverings determination of anti – slip properties wet-loaded barefoot areas; walking method – ramp test

**P CEN/TS 16165: 2013**

Determination of slip resistance of pedestrian surfaces – Methods of evaluation

**Product:** Ceramic tiles dry-pressed, EN 14411, Annex G, group BI<sub>a</sub> type: **WOOD 2.0** , format 59,3 x 59,3 cm  
**Producer:** **CERSANIT S. A.**, Al. Solidarności 36, 25-323 Kielce, Poland  
**Production Plant:** **OPOCZNO I SP.Z O.O.**, Ul. Przemysłowa 5, 26-300 Opoczno, Poland  
**Order:** Z 030190012

**Achieved values:**

Testing samples	Critical angle of slip classification according DIN 51097
<b>WOOD 2.0</b> , format 59,3 x 59,3 cm	20° <b>B</b>

The certificate is issued on the basis of the results of the tests stated in report no. 030–052527 from 30<sup>th</sup> November 2015.  
The certificate is extended the period of validity based on the manufacturer's assertion that the manufacturing technology remains unchanged.

Number of pages of certificate: 1

Certificate validity: **till 31<sup>st</sup> January 2022**

The certificate can be cancelled upon finding non-adherence to the certified parameters of product qualities.

Pilsen 1<sup>st</sup> January 2019



**Ing. Alexander Trinner**  
Branch Director

**Warning:** Without a written consent of the representative of the head of the authorised person, this report must not reproduced otherwise than in its entirety.

Technical and testing construction institute Prague, state enterprise, branch 0300 - Pilsen, Zahradní 15, 326 00 Pilsen, Czech Republic  
☎: 377 243 331, ☎: 377 430 345, Fax:+420 377 430 347, Internat.:+420 377 244 158, ✉ e-mail: babkova@tzus.cz, www.tzus.cz  
Banking details: KB Prague 1 Czech Republic, account number: 1501-931/0100 Co. Id. No.: 000 15679 Tax Co. Id. No.: CZ-00015679